

GLENDAL FIRE DEPARTMENT INSPECTION REPORT

- ☒ 1st Notice
☐ 2nd Notice
☐ Final Notice

File _____ Recheck 12-21-88 Date 12-14-88 Occupancy Class B-2 Inspection Area 28
Location 6628-6634 SAN FERNANDO Firm Name PENNOYER DODGE
Building Owner HAZEL DODGE Manager/Lessee HAZEL DODGE
Address 23366 LOS ENCINOS Address 23366 LOS ENCINOS
City GLENDAL Tel. 992-5659 City WOODLAND HILLS Tel. 818 240-1170
Contacted PHIL CRAWFORD (818) 240-1170 Title SHOP SUPV
REASONABLE FIRE SAFETY EXISTS THIS DATE 12-21-88 Inspector Dal Danitz

YOUR ATTENTION IS CALLED TO THE FOLLOWING VIOLATIONS OF THE ☐ UNIFORM FIRE CODE, ☐ UNIFORM BUILDING CODE, ☐ GLENDALE MUNICIPAL CODE, ☐ TITLE 19 C.A.C., ☐ _____

NOTE: VIOLATIONS ARE INDICATED BY CHECK MARKS ADJACENT TO NUMBERS

- ☐ 1. Provide _____ minimum _____ fire extinguisher(s) in a conspicuous and accessible location. Extinguisher(s) shall be U.L. approved and have the State Fire Marshal's Certification Tag attached.
- ☐ 2. Have your extinguisher(s) serviced by a qualified and licensed fire extinguisher concern in accordance with Title 19, C.A.C. This shall be done on a yearly basis.
- ☐ 3. Provide a complete test of the _____ system(s) within the building. All repairs and tests shall be made in accordance with recognized standards. ☐ Tests shall be witnessed by a fire department representative.
- ☐ 4. Remove temporary and unapproved electrical wiring from _____
☐ a. Install cover plates on all electrical outlets and junction boxes.
☐ b. Eliminate all multiple connections.
☐ c. Repair/replace defective or unapproved electrical cords/wiring.
- ☐ 5. It is unlawful to block open stairway and/or fire doors.
- ☐ 6. Immediately remove obstruction(s) to means of egress.
- ☐ 7. Repair exit door(s). Doors provided for egress shall be maintained.
- ☐ 8. Repair all holes in walls and/or ceilings.
- ☐ 9. Establish adequate aisles and passageways not less than _____ wide and keep same free and clear at all times.
- ☒ 10. Remove combustible storage/materials from/within HOT WATER HEATER (6634)
(6634) (6628)
- ☒ 11. Post a sign(s) indicating MAIN ELECTRIC PANEL (6634) EXIT SIGN
MOVE COMBUSTIBLES FROM HOT WATER HEATER
- ☐ 12. A general cleanup of the premises is indicated at this time.
- ☐ 13. Provide metal containers with tight-fitting lids for:
☐ a. Collection and storage of oily and greasy rags.
☐ b. Storage of all combustible rubbish and provide adequate pick-up service.
- ☐ 14. Provide an address on the front of the building that is clearly visible from street.
- ☐ 15. Apply at the Fire Prevention Bureau, 633 East Broadway, Room 303, Telephone (818) 956-4810 for a permit to: _____
- ☐ 16. Additional requirements and/or remarks _____

NOTE: FOR ADDITIONAL REQUIREMENTS AND/OR REMARKS, SEE ATTACHED SECOND PAGE.

A REINSPECTION OF THE PREMISES WILL BE MADE IN APPROXIMATELY 7 days FROM THE ABOVE DATE, AT WHICH TIME WE SHALL EXPECT SUBSTANTIAL COMPLIANCE WITH THESE REQUIREMENTS.

This inspection was conducted by: LOPERINA / SANCHEZ Inspector
ROBERT DODGE 818 247-7427

☐ Engine Company _____
☒ Truck Company 26 - B
☐ Fire Prev. Bureau _____
Tel. No. (818) 956-4026

SQ FT. - 20,000
STORIES - 2
PROTECTION SYSTEM
F-230a (2/84)
BLOCK

☒ Reasonable Fire Safety Exists At This

12-21-88

Da Dandy

☒ Violation Cleared

☐ Referred to Fire Prevention Division

COMPANY RESPONSIBILITIES

☐ Reinspection (Date) _____ Inspector _____

☐ Second Notice (Date) _____ Inspector _____

☐ Reinspection (Date) _____ Inspector _____

☐ Sent To Fire Prevention Bureau (Date) _____ Inspector _____

Comments _____

FIRE PREVENTION RESPONSIBILITIES

☐ Reinspection (Date) _____ Inspector _____

☐ Final Notice (Date) _____ Inspector _____

☐ Reinspection (Date) _____ Inspector _____

☐ Sent To City Attorney (Date) _____ Inspector _____

☐ Office Hearing (Date) _____ Inspector _____

☐ Reinspection (Date) _____ Inspector _____

☐ Court (Div. and Date) _____

Comments _____